

REGIONAL TESTING CENTRE (W.R.)

क्षेत्रीय परीक्षण केंद्र (प.के.)
 Government of India Ministry of SSI
 लघु उद्योग विभाग भारत सरकार,
 Kurla Andheri Road, Saki Naka,
 मुंबई वॉर्ल्ड 400 072, रावली भाग,
 Mumbai - 400 072.
 मुंबई - 400 072.



Tel. : (022) - 28370588/28571098/28571775
 दूरभाष : 28570588/28570998/28571775
 Grams : "REGTEST" MUMBAI - 72
 साय : रिजटेस्ट, मुंबई - 72
 Fax (022)-857 2238



परीक्षण / कॅलिब्रेशन रिपोर्ट
TEST / CALIBRATION REPORT

Contract No. T 0514

कार्य संख्या / Job Order No. **RTC/WR/ELECT/751/2003-04** तिथि / Date: **25.03.04** रिपोर्ट संख्या / Report No. **751**

को जारी किया / Issued to: **M/s.RELIANCE ENERGY LTD.** जारी करने की तिथि / Date of Issue: **24.04.2004**
 Copy to: M/s POLARIS CABLES & WIRES PVT.LTD., MUMBAI-400 049

पल पर पहचान चिह्न / Identification Mark: **POLARIS** आवेदन संख्या / Request No.: **N/A**
 तिथि / Issue: **23.03.2004**

वांछित परीक्षण / Test Required: **TYPE TEST AS PER IS: 1554 (PART-1) - 1988 (Specification for PVC insulated(heavy duty) electric cables for working voltages upto and including 1100V) including amend. 01.** सामान्य का ब्यौरा / Material Details: **8 mtrs of POLARIS CABLE 2 core Heavy Duty armoured cable with stranded aluminium conductor of size 10 mm², PVC insulated, colour coded, lead up cores & Black colour PVC outer sheath of voltage grade 1100V**

क्रम संख्या / Sr. No.	परीक्षण का नाम / Name of the Test	मानक विवरण / Standard Specification	वास्तविक परिणाम / Actual Sample Results	टिप्पणी / Remarks
1	IDENTIFICATION, PACKING & MARKING:			
1.1	MANUFACTURER'S IDENTIFICATION (Cl. 17.1): The manufacturer shall be identified throughout the length of the cable by name or trade mark being indented, printed or embossed on the outer sheath of the cable.		Date of Test : 12.04.04 POLARIS 1.1 KV ELECTRIC CABLE BEPL/PO170000042 30.01.03.2004 PVC INSULATED (TYPE A) PVC SHEATHED (TYPE ST1) BRP embossed	Passer
1.2	Cable Identification (Cl. 17.2):- Outer sheath of the cable shall be indented, printed or embossed throughout the length the word "ELECTRIC" or "MINING" as applicable.		ELECTRIC embossed	Passer

टिप्पणी : यह रिपोर्ट परीक्षण के लिए प्रेषित नमूने पर आधारित है। इस रिपोर्ट को प्रकाशित करने से पहले परीक्षण केंद्र को सूचित किया जाना चाहिए। रिपोर्ट जारी करने के 30 दिनों के भीतर ही नमूने को वापस लेना आवश्यक है। अन्यथा, नमूने का स्वामित्व परीक्षण केंद्र के पास रहेगा।

1) This report pertains to the particular sample submitted for test.
 2) This report may not be reproduced without prior written permission of RTC Mumbai.
 3) This tested sample(s) should be collected positively within 30 days from issue of this report, failing which no claim whatsoever and no correspondence in matter shall be entertained and such sample(s) will be disposed off per Government Procedure.

Page No. 1 of 6 Job Order No. **R.T.C./WR/ELECT/751/2003-04**
 Asst. Director (Elect)
 NABL