



TUV INDIA PVT. LTD.
 801, RAHEJA PLAZA - 1, LBS MARG
 GHATKOPAR (W), MUMBAI - 400 086, INDIA.

INSPECTION RELEASE NOTE

Client : Reliance Petroleum Limited	Office : Mumbai	IRN NO. 10106306/ 39
Project : Jamnagar Expansion Refinery Project		Date : 06-02-2007
Main Order Number : 25194-JGZ-EG1L01/MDC dated 11.11.2006	On : M/s. Polaris Cables & Wires Pvt. Ltd.	
Sub-Order Number : --	On : --	
Inspection Date : From 03.02.2007 to --	Order Status : <input type="checkbox"/> Complete <input checked="" type="checkbox"/> Incomplete	

THE FOLLOWING WAS FINALLY ACCEPTED:-

P. O. Item Number	Description	Quantity Passed	Is Item Complete?
1	1 C X 35 Sq. MM. AL / PVC Cable for Earthing	25099	No
2	1 C X 70 Sq. MM. AL / PVC Cable for Earthing.	5522	No
Detail of Quantities as per "Offer List" attached.			
1. GA Drawing No. 25194-JGZ-EG1L01-MDC-000 dated B01 - 002			
2. ITP No. 25194-JGZ-EG1L01-MDC-000-A08-001			
3. Data sheet - 25194-JGZ-EG1L01-MDC-000-D01-0001			
Stage & Final inspection carried out as per above ITP, and results were found acceptable against relevant procedures and specification referred in ITP.			

This issue of release note does not relieve the supplier / manufacturer from its responsibility to the client to supply the item(s) concerned in full compliance with requirements of its order specification.

Stickers with " " stamp pasted on both ends of the cable.	Surveyor N. G. Tamane
--	------------------------------